

CONTROL OF POLLUTION (OIL STORAGE)(ENGLAND) REGULATIONS 2001

The above Regulations came into effect for new oil stores from March 2002.

Existing oil stores 'at significant risk' will have to comply from 1 September 2003; all remaining existing oil stores have to comply from 1 September 2005.

An oil store is considered 'at significant risk' of it is:

- Located within 10 metres of a water course, or
- Located within 50 metres of a well or bore hole

The Regulations require owners of oil tanks to provide a secondary containment facility, such as a bund or drip tray, to prevent oil escaping into the water environment.

The Regulations apply to virtually all premises where more than 200 litres of oil are stored above ground at an industrial, commercial or institutional site, or more than 3,500 litres at a domestic site. The Regulations apply to factories, shops and offices, hotels, schools, public sector buildings and hospitals, **and churches**.

The Regulations cover all types of oil, including petrol, diesel, vegetable, synthetic and mineral oil.

The standards required by the Regulations are as follows:

- Tanks, drums or other containers must be strong enough to hold the oil without leaking or bursting
- If possible, the oil container must be positioned away from any vehicle traffic to avoid damage by collision
- A bund or drip tray must be provided to catch any leaking from the container or its ancillary pipework and equipment
- The bund must be sufficient to contain 110% of the maximum content of the oil container
- Where oil is stored in more than one container, the bund should be capable of storing 110% of the largest tank or 25% of the total storage capacity, whichever is the greater
- The bund base and walls must be impermeable to water and oil must be checked regularly for leaks
- Any valve, filter, site gauge, vent pipe or other ancillary equipment must be kept within the bund when not in use
- No drainage valve may be fitted to the bund for the purposes of draining out rain water
- Above-ground pipework should be properly supported
- Underground pipework should be protected from physical damage and have adequate leakage protection
- If mechanical joints must be used, they should be readily accessible for inspection

The Regulations also apply to drums over 200 litres and to mobile bowsters. Bowsters that are not self-bunded will need to be kept in a bunded area or drip tray when not in use.

For single drums, a drip tray with a capacity of 25% is acceptable.

Double-skinned tanks do not automatically comply with Regulations. This is because the site gauge and other pipework are outside the double skin. If the inner tank, site gauge and pipework are completely contained within a totally enclosed unit then it may comply with the Regulations. The Environment Agency advise that details should be obtained from the manufacturer and referred to them for approval.

The Environment Agency is responsible for enforcing the Regulations and will provide advice and guidance to help with compliance. Failure to comply could result in the issue of an improvement notice. Failure to comply with an improvement notice is a criminal offence and may result in prosecution.

Further information : www.environment-agency.gov.uk